

Toplotna bilanca

N1-	PRITLIČJE								
S1-	PISARNE								
P	Prostor	tn (°C)	Qn (W)	PhiT (W)	PhiV (W)	Qi(dvo) (W)	Qi(vk) (W)	Qinst (W)	Qost (W)
P1-	HODNIK-VETROLOV	20	945	480	465	1309	0	1309	-364
P2-	PISARNA 23	20	1207	960	247	0	0	0	1207
P4-	PISARNA 22	20	1612	915	697	0	0	0	1612
P5-	PISARNA 28	20	746	552	194	0	0	0	746
P6-	ČAJNA KUHINJA	20	887	551	336	0	0	0	887
P7-	WC M	20	179	110	69	279	0	279	-100
P8-	WC Ž	20	113	71	42	279	0	279	-166
	Skupno: PISARNE		5689	3639	2050	1867	0	1867	3822
S2-	GARDEROBE								
P	Prostor	tn (°C)	Qn (W)	PhiT (W)	PhiV (W)	Qi(dvo) (W)	Qi(vk) (W)	Qinst (W)	Qost (W)
P9-	GARDEROBA	20	13840	5296	8544	0	0	0	13840
P10-	GARDEROBA Ž	20	4115	3015	1100	0	0	0	4115
P11-	KOPALNICA Ž	24	2118	1546	572	2510	0	2510	-392
P12-	KOPALNICA M	20	633	148	485	1144	0	1144	-511
P13-	WC M	20	1102	526	576	1481	0	1481	-379
P14-	VETROLOV	20	1003	698	305	1253	0	1253	-250
P15-	ČISTILA	20	351	248	103	0	0	0	351
P16-	ČAJNA KUHINJA	20	2748	1858	890	3142	0	3142	-394
P17-	ČAJNA KUHINJA Ž	20	2044	1603	441	2221	0	2221	-177
	Skupno: GARDEROBE		27954	14938	13016	11751	0	11751	16203
	Skupno: PRITLIČJE		33643	18577	15066	13618	0	13618	20025
N2-	NADSTROPJE								
S1-	PISARNE								
P	Prostor	tn (°C)	Qn (W)	PhiT (W)	PhiV (W)	Qi(dvo) (W)	Qi(vk) (W)	Qinst (W)	Qost (W)
P1-	HODNIK	20	2107	1261	846	2094	0	2094	13
P2-	DIREKTOR	20	2669	2026	643	0	0	0	2669
P3-	PISARNA 12	20	615	446	169	0	0	0	615
P4-	WC M	20	631	462	169	785	0	785	-154
P5-	ČAJNA KUHINJA	20	278	211	67	785	0	785	-507
P6-	WC Ž	20	666	541	125	785	0	785	-119
P7-	PISARNA	20	963	762	201	0	0	0	963
P8-	PISARNA 01	20	1772	1388	384	0	0	0	1772
P9-	PISARNA	20	2438	1998	440	0	0	0	2438
P10-	SEJNA SOBA	20	580	445	135	0	0	0	580
P11-	PISARNA	20	1660	1235	425	0	0	0	1660
P12-	PISARNA 09	20	870	694	176	0	0	0	870
P13-	PISARNA 10	20	1660	1235	425	0	0	0	1660
P14-	PISARNA 11	20	1643	1373	270	0	0	0	1643
	Skupno: PISARNE		18552	14077	4475	4449	0	4449	14103
	Skupno: NADSTROPJE		18552	14077	4475	4449	0	4449	14103
	Skupno:		52195	32654	19541	18067	0	18067	34128
Tip zgradbe		Ostale zgradbe							
Konstrukcija		Lahka							
Zaščitni razred		Nezaščiten tip							
Stopnja zatesnjenosti		Povprečni							
Število izmenjav zraka pri 50 (Pa):		5,0 (1/h)							
Temperature									
Zunanja projektna temperatura		-4 (°C)							
Srednja letna temperatura		13,0 (°C)							