



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani



Rezultati označeni z # se nanašajo na
neakreditirano dejavnost.

Test report No.: 1277/21

Date: 30.08.21 Page: 1 from 1

Sample: **Drinking water**

Client: **Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper**

		Date of sampling:	25.08.21
Sample label:	Passenger terminal, bond 2, hydrant (sampled 8:30)		
Received on:	25.08.21	Lab.ref.:	1277/21

ANALYSIS REPORT:

Property	Unit	Test Method	Limit value	Result	Mark
Field measurements					
Water temperature	°C	SIST DIN 38404-4:2000	-	17,6	#
Free chlorine dioxide	mg/l	Internal method	-	0,16	#
pH		SIST ISO 10523:2010	6,5-9,5	7,64	#
Conductivity (at 20°C)	uS/cm	SIST EN 27888:1998	< 2500	376	#
Smell	organoleptic attribute	SIST EN 1622:2007	acceptable	acceptable	#

Physicochemical properties

Colour *	m-1	SIST EN ISO 7887:2012 (method B)	< 0,50	<0,1	#
Turbidity *	NTU	SIST EN ISO 7027:2000	≤ 1,0	0,16	#
Ammonium	mg/l NH4	SIST ISO 7150-1:1996	< 0,50	<0,01	#
Taste	organoleptic attribute	SIST EN 1622:2007	acceptable	acceptable	#

Microbiological properties

<i>Escherichia coli (E.coli)</i>	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	
Coliform bacteria	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	#
<i>Clostridium perfringens</i>	cfu/100ml	SIST ISO 14189:2014	0	not detected	#
Total viable count at 36°C	cfu/ml	SIST EN ISO 6222:1999	< 100	detected	
Intestinal enterococci	cfu/100ml	SIST EN ISO 7899-2:2000	0	not detected	#
Total viable count at 22°C *	cfu/ml	SIST EN ISO 6222:1999	< 100	detected	

Note: not detected (0 cfu), detected (<4 cfu), est. (estimated)

Results shown in **bold** type do not conform with the limit values in the criteria regulations concerned.

Information about uncertainty are available in the laboratory.

The results marked with # refers to **non-accredited** method.

Regulations taken into account:

Rules on drinking water (UR.I.RS nos. 19/04, 35/04, 26/06, 92/06, 25/09, 74/15 and 51/17).

*Description of indicator parameters found in drinking water (NIJZ, Version 2, June 2014)

Analysis performed: from 25.8.21 (15:00) to 28.8.21 (09:30)

Analyst:

Kaja Jerman, B.Sc. Microbiol

Head of lab.:

Ankica Budan Hadžalič, B.Sc.

The results of accordance verification refer exclusively to verified samples. The report should not be reproduced without a previous written approval, unless it is reproduced as a whole unit.