



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani

Report No.: 1513/26-T

Date: 13.08.26 Page: 1 from 1

Sample: Drinking water

Client: Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper

Client provided data:	Date of sampling: 10.08.26
Sample label:	Passenger terminal, Bond 1, hydrant

Received on: 10.08.26

Lab.ref.: 1513/26-T

ANALYSIS REPORT:

Property	Unit	Test Method	Limit value	Result
Field measurments				
Water temperature	°C	SIST DIN 38404-4:2000	-	20,4
Free chlorine	mg/l	Internal method	-	0,12
pH value		SIST ISO 10523:2010	6,5-9,5	7,81
Conductivity (at 20°C)	uS/cm	SIST EN 27888:1998	< 2500	424
Smell	organoleptic attribute	SIST EN 1622:2007	acceptable	acceptable

Regulations taken into account:

Drinking water regulations (UR.I.RS nos.61/23, 192/26)

Analysis performed: from 10.08.26 to 10.08.26

Microbiologist:
Kaja Jerman, B.Sc. Microbiol.

Head of lab.:
Ankica Budan Hadžalič, B.Sc.