



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani



Report No.: 1514/26

Date: 13.08.26 *Page:* 1 *from* 1

Sample: **Drinking water**

Client: **Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper**

Client provided data:

Date of sampling: **10.08.26**

Sample label: **Passenger terminal, Bond 2, hydrant**

Received on: **10.08.26**

Lab.ref.: **1514/26**

ANALYSIS REPORT:

Property	Unit	Test Method	Limit value	Result	Mark
Physicochemical properties					
Colour	m-1	SIST EN ISO 7887:2012 (method B)	-	<0,1	#
Turbidity	NTU	SIST EN ISO 7027-1:2017	4,0	0,24	#
Ammonium	mg/l NH ₄	SIST ISO 7150-1:1996	< 0,50	<0,01	#
Taste	organoleptic attribute	SIST EN 1622:2007	acceptable	acceptable	#

Microbiological properties

Escherichia coli (E.coli)	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	
Coliform bacteria	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	#
Clostridium perfringens	cfu/100ml	SIST ISO 14189:2014	0	not detected	#
Total number of culturable microorganisms at 36°C	cfu/ml	SIST EN ISO 6222:1999	< 100	presence	
Intestinal enterococci	cfu/100ml	SIST EN ISO 7899-2:2000	0	not detected	#
Total number of culturable microorganisms at 22°C	cfu/ml	SIST EN ISO 6222:1999	-	presence	

Note: not detected (0 cfu), presence (1-2 cfu), est. (estimated)

Information about uncertainty are available in the laboratory.

Regulations taken into account:

Drinking water regulations (UR.I.RS nos.61/23, 192/26)

Analysis performed: from **10.08.26 (15:00)** to **13.08.26 (11:00)**

Microbiologist:
Kaja Jerman, B.Sc. Microbiol.

Head of lab.:
Ankica Budan Hadžalič, B.Sc.