



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani

Date: 17.04.2026

FINAL EVALUATION FOR TEST REPORTS No.: 717/26 AND 717/26-T

Evaluation of compliance with the regulations taken into account: The sample is **compliant** with the Drinking water regulations (UR.I.RS nos.61/23).

Analyst:

Kaja Jerman, B.Sc.Microbiol.

Head of lab:

Ankica Budan Hadžalić, B. Sc.



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani



Report No.: 717/26

Date: 17.04.26 Page: 1 from 1

Sample: **Drinking water**

Client: **Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper**

Client provided data:	Date of sampling: 14.04.26
Sample label:	Passenger terminal, Bond 1, hydrant

Received on: **14.04.26**

Lab.ref.: **717/26**

ANALYSIS REPORT:

Property	Unit	Test Method	Limit value	Result	Mark
Physicochemical properties					
Colour	m-1	SIST EN ISO 7887:2012 (method B)	-	<0,1	#
Turbidity	NTU	SIST EN ISO 7027-1:2017	4,0	0,06	#
Ammonium	mg/l NH ₄	SIST ISO 7150-1:1996	< 0,50	<0,01	#
Taste	organoleptic attribute	SIST EN 1622:2007	acceptable	acceptable	#
Microbiological properties					
<i>Escherichia coli (E.coli)</i>	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	
Coliform bacteria	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	#
<i>Clostridium perfringens</i>	cfu/100ml	SIST ISO 14189:2014	0	not detected	#
Total number of culturable microorganisms at 36°C	cfu/ml	SIST EN ISO 6222:1999	< 100	not detected	
Intestinal enterococci	cfu/100ml	SIST EN ISO 7899-2:2000	0	not detected	#
Total number of culturable microorganisms at 22°C	cfu/ml	SIST EN ISO 6222:1999	-	not detected	

Note: not detected (0 cfu), presence (1-2 cfu), est. (estimated)

Information about uncertainty are available in the laboratory.

Regulations taken into account:

Drinking water regulations (UR.I.RS nos.61/23)

Analysis performed: from **14.04.26 (14:00)** to **17.04.26 (08:30)**

Microbiologist:
Kaja Jerman, B.Sc. Microbiol.

Head of lab.:
Ankica Budan Hadžalič, B.Sc.



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani

Report No.: 717/26-T

Date: 17.04.26 Page: 1 from 1

Sample: **Drinking water**

Client: **Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper**

Client provided data:	Date of sampling: 14.04.26
Sample label: Passenger terminal, Bond 1, hydrant	

Received on: **14.04.26**

Lab.ref.: **717/26-T**

ANALYSIS REPORT:

Property	Unit	Test Method	Limit value	Result
Field measurements				
Water temperature	°C	SIST DIN 38404-4:2000	-	13,6
Free chlorine	mg/l	Internal method	-	0,03
pH value		SIST ISO 10523:2010	6,5-9,5	6,88
Conductivity (at 20°C)	uS/cm	SIST EN 27888:1998	< 2500	430
Smell	organoleptic attribute	SIST EN 1622:2007	acceptable	acceptable

Regulations taken into account:

Drinking water regulations (UR.I.RS nos.61/23)

Analysis performed: from **14.04.26** to **14.04.26**

Microbiologist:
Kaja Jerman, B.Sc. Microbiol.

Head of lab.:
Ankica Budan Hadžalič, B.Sc.



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani

Date: 17.04.2026

FINAL EVALUATION FOR TEST REPORTS No.: 718/26 AND 718/26-T

Evaluation of compliance with the regulations taken into account: The sample is **compliant** with the Drinking water regulations (UR.I.RS nos.61/23).

Analyst:

Kaja Jerman, B.Sc.Microbiol.

Head of lab:

Ankica Budan Hadžalić, B. Sc.



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani



Report No.: 718/26

Date: 17.04.26 Page: 1 from 1

Sample: **Drinking water**

Client: **Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper**

Client provided data:	Date of sampling: 14.04.26
Sample label:	Passenger terminal, Bond 2, hydrant

Received on: **14.04.26**

Lab.ref.: **718/26**

ANALYSIS REPORT:

Property	Unit	Test Method	Limit value	Result	Mark
Physicochemical properties					
Colour	m-1	SIST EN ISO 7887:2012 (method B)	-	<0,1	#
Turbidity	NTU	SIST EN ISO 7027-1:2017	4,0	0,09	#
Ammonium	mg/l NH ₄	SIST ISO 7150-1:1996	< 0,50	<0,01	#
Taste	organoleptic attribute	SIST EN 1622:2007	acceptable	acceptable	#
Microbiological properties					
<i>Escherichia coli (E.coli)</i>	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	
Coliform bacteria	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	#
<i>Clostridium perfringens</i>	cfu/100ml	SIST ISO 14189:2014	0	not detected	#
Total number of culturable microorganisms at 36°C	cfu/ml	SIST EN ISO 6222:1999	< 100	not detected	
Intestinal enterococci	cfu/100ml	SIST EN ISO 7899-2:2000	0	not detected	#
Total number of culturable microorganisms at 22°C	cfu/ml	SIST EN ISO 6222:1999	-	not detected	

Note: not detected (0 cfu), presence (1-2 cfu), est. (estimated)

Information about uncertainty are available in the laboratory.

Regulations taken into account:

Drinking water regulations (UR.I.RS nos.61/23)

Analysis performed: from **14.04.26 (14:00)** to **17.04.26 (08:30)**

Microbiologist:
Kaja Jerman, B.Sc. Microbiol.

Head of lab.:
Ankica Budan Hadžalič, B.Sc.



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani

Report No.: 718/26-T

Date: 17.04.26 Page: 1 from 1

Sample: **Drinking water**

Client: **Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper**

Client provided data:	Date of sampling: 14.04.26
Sample label: Passenger terminal, Bond 2, hydrant	

Received on: **14.04.26**

Lab.ref.: **718/26-T**

ANALYSIS REPORT:

Property	Unit	Test Method	Limit value	Result
Field measurements				
Water temperature	°C	SIST DIN 38404-4:2000	-	14,0
Free chlorine	mg/l	Internal method	-	0,07
pH value		SIST ISO 10523:2010	6,5-9,5	7,08
Conductivity (at 20°C)	uS/cm	SIST EN 27888:1998	< 2500	433
Smell	organoleptic attribute	SIST EN 1622:2007	acceptable	acceptable

Regulations taken into account:

Drinking water regulations (UR.I.RS nos.61/23)

Analysis performed: from **14.04.26** to **14.04.26**

Microbiologist:
Kaja Jerman, B.Sc. Microbiol.

Head of lab.:
Ankica Budan Hadžalič, B.Sc.