



Tehnološko okoljski in logistični center d.o.o.  
Dekani 3a, SI-6271 Dekani



**SLOVENSKA  
AKREDITACIJA**  
SIST EN ISO/IEC 17025  
**LP-093**

The results marked by # relate to non-accredited activity

**Report No.:** 567/26

Date: 27.03.26 Page: 1 from 1

Sample: **Drinking water**  
Client: **Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper**

Client provided data: Date of sampling: **23.03.26**

Sample label: **Passenger terminal, Bond 1, Hydrant**

Received on: **23.03.26**

Lab.ref.: **567/26**

**ANALYSIS REPORT:**

Property	Unit	Test Method	Limit value	Result	Mark
<b>Physicochemical properties</b>					
Colour	m-1	SIST EN ISO 7887:2012 (method B)	-	<0,1	#
Turbidity	NTU	SIST EN ISO 7027-1:2017	4,0	0,07	#
Ammonium	mg/l NH4	SIST ISO 7150-1:1996	< 0,50	<0,01	#
Taste	organoleptic attribute	SIST EN 1622:2007	acceptable	not detected	#
<b>Microbiological properties</b>					
<i>Escherichia coli (E.coli)</i>	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	
Coliform bacteria	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	#
<i>Clostridium perfringens</i>	cfu/100ml	SIST ISO 14189:2014	0	not detected	#
Total number of culturable microorganisms at 36°C	cfu/ml	SIST EN ISO 6222:1999	< 100	not detected	
Intestinal enterococci	cfu/100ml	SIST EN ISO 7899-2:2000	0	not detected	#
Total number of culturable microorganisms at 22°C	cfu/ml	SIST EN ISO 6222:1999	-	not detected	

Note: not detected (0 cfu), presence (1-2 cfu), est. (estimated)

Information about uncertainty are available in the laboratory.

**Regulations taken into account:**

Drinking water regulations (UR.I.RS nos.61/23)

Analysis performed: from 23.03.26 (13:00) to 26.03.26 (09:30)

Microbiologist:  
Kaja Jerman, B.Sc. Microbiol.

Head of lab.:  
Ankica Budan Hadžalič, B.Sc.



Tehnološko okoljski in logistični center d.o.o.  
Dekani 3a, SI-6271 Dekani

**Report No.:** 567/26-T

*Date:* 27.03.26 *Page:* 1 *from* 1

*Sample:* **Drinking water**

*Client:* **Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper**

**Client provided data:** Date of sampling: **23.03.26**

*Sample label:* **Passenger terminal, Bond 1, Hydrant**

*Received on:* **23.03.26**

*Lab.ref.:* **567/26-T**

**ANALYSIS REPORT:**

Property	Unit	Test Method	Limit value	Result
<b>Field measurments</b>				
Water temperature	°C	SIST DIN 38404-4:2000	-	14,0
Free chlorine	mg/l	Internal method	-	0,06
pH value		SIST ISO 10523:2010	6,5-9,5	7,61
Conductivity (at 20°C)	uS/cm	SIST EN 27888:1998	< 2500	429
Smell	organoleptic attribute	SIST EN 1622:2007	acceptable	acceptable

**Regulations taken into account:**

Drinking water regulations (UR.I.RS nos.61/23)

Analysis performed: from 23.03.26 to 23.03.26

Microbiologist:  
Kaja Jerman, B.Sc. Microbiol.

Head of lab.:  
Ankica Budan Hadžalič, B.Sc.



Tehnološko okoljski in logistični center d.o.o.  
Dekani 3a, SI-6271 Dekani



The results marked by # relate to non-accredited activity

**Report No.:** 568/26

Date: 27.03.26 Page: 1 from 1

Sample: **Drinking water**  
Client: **Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper**

Client provided data: Date of sampling: **23.03.26**

Sample label: **Passenger terminal, Bond 2, Hydrant**

Received on: **23.03.26**

Lab.ref.: **568/26**

**ANALYSIS REPORT:**

Property	Unit	Test Method	Limit value	Result	Mark
<b>Physicochemical properties</b>					
Colour	m-1	SIST EN ISO 7887:2012 (method B)	-	<0,1	#
Turbidity	NTU	SIST EN ISO 7027-1:2017	4,0	0,06	#
Ammonium	mg/l NH4	SIST ISO 7150-1:1996	< 0,50	<0,01	#
Taste	organoleptic attribute	SIST EN 1622:2007	acceptable	not detected	#
<b>Microbiological properties</b>					
<i>Escherichia coli (E.coli)</i>	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	
Coliform bacteria	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	#
<i>Clostridium perfringens</i>	cfu/100ml	SIST ISO 14189:2014	0	not detected	#
Total number of culturable microorganisms at 36°C	cfu/ml	SIST EN ISO 6222:1999	< 100	not detected	
Intestinal enterococci	cfu/100ml	SIST EN ISO 7899-2:2000	0	not detected	#
Total number of culturable microorganisms at 22°C	cfu/ml	SIST EN ISO 6222:1999	-	not detected	

Note: not detected (0 cfu), presence (1-2 cfu), est. (estimated)

Information about uncertainty are available in the laboratory.

**Regulations taken into account:**

Drinking water regulations (UR.I.RS nos.61/23)

Analysis performed: from 23.03.26 (13:00) to 26.03.26 (09:30)

Microbiologist:  
Kaja Jerman, B.Sc. Microbiol.

Head of lab.:  
Ankica Budan Hadžalič, B.Sc.



Tehnološko okoljski in logistični center d.o.o.  
Dekani 3a, SI-6271 Dekani

**Report No.:** 568/26-T

Date: 27.03.26 Page: 1 from 1

Sample: **Drinking water**

Client: **Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper**

Client provided data: Date of sampling: **23.03.26**

Sample label: **Passenger terminal, Bond 2, Hydrant**

Received on: **23.03.26**

Lab.ref.: **568/26-T**

**ANALYSIS REPORT:**

Property	Unit	Test Method	Limit value	Result
<b>Field measurements</b>				
Water temperature	°C	SIST DIN 38404-4:2000	-	13,4
Free chlorine	mg/l	Internal method	-	0,09
pH value		SIST ISO 10523:2010	6,5-9,5	8,08
Conductivity (at 20°C)	uS/cm	SIST EN 27888:1998	< 2500	446
Smell	organoleptic attribute	SIST EN 1622:2007	acceptable	acceptable

**Regulations taken into account:**

Drinking water regulations (UR.I.RS nos.61/23)

Analysis performed: from 23.03.26 to 23.03.26

Microbiologist:  
Kaja Jerman, B.Sc. Microbiol.

Head of lab.:  
Ankica Budan Hadžalič, B.Sc.