



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani



**SLOVENSKA
AKREDITACIJA**
SIST EN ISO/IEC 17025
LP-093

The results marked by # relate to
non-accredited activity

Report No.: 701/25

Date: 29.05.25 *Page:* 1 *from* 1

Sample: **Drinking water**

Client: **Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper**

Client provided data:	<i>Date of sampling:</i> 26.05.25
<i>Sample label:</i>	Passenger terminal, Bond 1, hydrant (Sampled at 9:40)

Received on: **26.05.25**

Lab.ref.: **701/25**

ANALYSIS REPORT:

Property	Unit	Test Method	Limit value	Result	Mark
Physicochemical properties					
Colour	m-1	SIST EN ISO 7887:2012 (method B)	-	<0,1	#
Turbidity	NTU	SIST EN ISO 7027-1:2017	4,0	0,08	#
Ammonium	mg/l NH ₄	SIST ISO 7150-1:1996	< 0,50	<0,01	#
Taste	organoleptic attribute	SIST EN 1622:2007	acceptable	acceptable	#
Microbiological properties					
Escherichia coli (E.coli)	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	
Coliform bacteria	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	#
Clostridium perfringens	cfu/100ml	SIST ISO 14189:2014	0	not detected	#
Total number of culturable microorganisms at 36°C	cfu/ml	SIST EN ISO 6222:1999	< 100	detected	
Intestinal enterococci	cfu/100ml	SIST EN ISO 7899-2:2000	0	not detected	#
Total number of culturable microorganisms at 22°C	cfu/ml	SIST EN ISO 6222:1999	-	detected	

Note: not detected (0 cfu), presence (1-2 cfu), est. (estimated)

Information about uncertainty are available in the laboratory.

Regulations taken into account:

Drinking water regulations (UR.I.RS nos.61/23)

Analysis performed: from **26.5.25 (14:00)** to **29.5.25 (10:30)**

Microbiologist:
Kaja Jerman, B.Sc. Microbiol.

Head of lab.:
Ankica Budan Hadžalič, B.Sc.



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani

Report No.: 701/25-T

Date: 29.05.25 *Page:* 1 *from* 1

Sample: **Drinking water**

Client: **Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper**

Client provided data:	<i>Date of sampling:</i> 26.05.25
<i>Sample label:</i>	Passenger terminal, Bond 1, hydrant (Sampled at 9:40)

Received on: **26.05.25**

Lab.ref.: **701/25-T**

ANALYSIS REPORT:

Property	Unit	Test Method	Limit value	Result
Field measurments				
Water temperature	°C	SIST DIN 38404-4:2000	-	18,8
Free chlorine	mg/l	Internal method	-	<0,01
pH value		SIST ISO 10523:2010	6,5-9,5	7,07
Conductivity (at 20°C)	uS/cm	SIST EN 27888:1998	< 2500	378
Smell	organoleptic attribute	SIST EN 1622:2007	acceptable	acceptable

Regulations taken into account:

Drinking water regulations (UR.I.RS nos.61/23)

Analysis performed: from 26.5.25 to 26.5.25

Microbiologist:
Kaja Jerman, B.Sc. Microbiol.

Head of lab.:
Ankica Budan Hadžalič, B.Sc.



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani



**SLOVENSKA
AKREDITACIJA**
SIST EN ISO/IEC 17025
LP-093

The results marked by # relate to
non-accredited activity

Report No.: 702/25

Date: 29.05.25 *Page:* 1 *from* 1

Sample: **Drinking water**

Client: **Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper**

Client provided data:	<i>Date of sampling:</i> 26.05.25
<i>Sample label:</i>	Passenger terminal, Bond 2, hydrant (Sampled at 10:00)

Received on: **26.05.25**

Lab.ref.: **702/25**

ANALYSIS REPORT:

Property	Unit	Test Method	Limit value	Result	Mark
Physicochemical properties					
Colour	m-1	SIST EN ISO 7887:2012 (method B)	-	<0,1	#
Turbidity	NTU	SIST EN ISO 7027-1:2017	4,0	0,06	#
Ammonium	mg/l NH ₄	SIST ISO 7150-1:1996	< 0,50	<0,01	#
Taste	organoleptic attribute	SIST EN 1622:2007	acceptable	acceptable	#
Microbiological properties					
Escherichia coli (E.coli)	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	
Coliform bacteria	cfu/100ml	SIST EN ISO 9308-1:2014	0	not detected	#
Clostridium perfringens	cfu/100ml	SIST ISO 14189:2014	0	not detected	#
Total number of culturable microorganisms at 36°C	cfu/ml	SIST EN ISO 6222:1999	< 100	not detected	
Intestinal enterococci	cfu/100ml	SIST EN ISO 7899-2:2000	0	not detected	#
Total number of culturable microorganisms at 22°C	cfu/ml	SIST EN ISO 6222:1999	-	detected	

Note: not detected (0 cfu), presence (1-2 cfu), est. (estimated)

Information about uncertainty are available in the laboratory.

Regulations taken into account:

Drinking water regulations (UR.I.RS nos.61/23)

Analysis performed: from **26.5.25 (14:00)** to **29.5.25 (10:30)**

Microbiologist:
Kaja Jerman, B.Sc. Microbiol.

Head of lab.:
Ankica Budan Hadžalič, B.Sc.



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani

Report No.: 702/25-T

Date: 29.05.25 *Page:* 1 *from* 1

Sample: **Drinking water**

Client: **Luka Koper d.d., Vojkovo nabrežje 38, 6000 Koper**

Client provided data:	<i>Date of sampling:</i> 26.05.25
<i>Sample label:</i>	Passenger terminal, Bond 2, hydrant (Sampled at 10:00)

Received on: **26.05.25**

Lab.ref.: **702/25-T**

ANALYSIS REPORT:

Property	Unit	Test Method	Limit value	Result
Field measurments				
Water temperature	°C	SIST DIN 38404-4:2000	-	19,4
Free chlorine	mg/l	Internal method	-	0,02
pH value		SIST ISO 10523:2010	6,5-9,5	7,87
Conductivity (at 20°C)	uS/cm	SIST EN 27888:1998	< 2500	387
Smell	organoleptic attribute	SIST EN 1622:2007	acceptable	acceptable

Regulations taken into account:

Drinking water regulations (UR.I.RS nos.61/23)

Analysis performed: from **26.5.25** to **26.5.25**

Microbiologist:
Kaja Jerman, B.Sc. Microbiol.

Head of lab.:
Ankica Budan Hadžalič, B.Sc.



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani

Date: 29.05.2025

FINAL EVALUATION FOR TEST REPORTS No.: 701/25 and 701/25-T

Evaluation of compliance with the regulations taken into account: The sample is **compliant** with the Drinking water regulations (UR.I.RS nos.61/23).

Analyst:

Kaja Jerman, B.Sc.Microbiol.

Head of lab:

Ankica Budan Hadžalić, B. Sc.



Tehnološko okoljski in logistični center d.o.o.
Dekani 3a, SI-6271 Dekani

Date: 29.05.2025

FINAL EVALUATION FOR TEST REPORTS No.: 702/25 and 702/25-T

Evaluation of compliance with the regulations taken into account: The sample is **compliant** with the Drinking water regulations (UR.I.RS nos.61/23).

Analyst:

Kaja Jerman, B.Sc.Microbiol.

Head of lab:

Ankica Budan Hadžalić, B. Sc.